

Westford Fire District No. 1

PO Box 103, Westford, VT 05494 ~ www.wfd1.org

Consumer Confidence Report **Water Quality Report - 2013**

Westford Fire District #1 (WFD #1) is classified and permitted as a groundwater, non-purchased public water system, operating under the Vermont State Water System Identification Number of:

WSID #5450

Our goal is to provide you with a safe and dependable supply of drinking water.

This report is a snapshot of the quality of water that we provided for 2013. It also includes the date and results of any contaminants that we detected within the past five years, of those that require testing less than once a year. Any contaminants detected within the past five years are listed along with the date of detection and concentration. This report is designed to inform you about the quality water and services we deliver to you every day.

Water Source Information:

The source(s) of our drinking water are 3 state-approved ground water wells. The well designations are: Well #1, Well #2 & Well #3.

Source Protection Plan:

Our source protection plan is available to you at any time and provides specific information about our water system, including potential sources of contamination. For more information about contaminants and potential health effects, please contact the EPA's Safe Drinking Water Hotline at 1-800-426-4791.

An overview of drinking water sources and the contaminants they may contain:

Possible sources of drinking water (both tap water and bottled water) include surface water (streams, lakes) and ground water (wells, springs).

As water travels over the land's surface or through the ground, it dissolves naturally occurring minerals. It also picks up substances resulting from human activity and the presence of animals. Some of these "contaminants" may be harmful. Others, such as iron and sulfur, are not.

Public water systems treat water to remove contaminants if any are present. In order to ensure that your water is safe to drink, we test it regularly according to regulations established by the U.S. Environmental Protection Agency and the State of Vermont. These regulations limit the amount of various contaminants:

- ***Microbial organisms*** (viruses and bacteria) may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- ***Inorganic chemicals - 'IOC'*** (salts and metals) can be naturally occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, or farming.
- ***Synthetic Organic chemicals - 'SOC'*** (pesticides and herbicides) may come from agriculture, urban storm water runoff, residential uses, and careless disposal of household chemicals.
- ***Volatile Organic chemicals - 'VOC'*** (gasoline and solvents) may come from gas stations, urban storm water runoff, septic systems, industrial process, and careless disposal of household chemicals.
- ***Naturally occurring radioactivity***

WATER QUALITY DATA

Terms and Abbreviations:

In the following tables you may find terms you might not be familiar with. To help you better understand these terms we have provided the following definitions:

Maximum Contamination Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.

Maximum Contamination Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of disinfectants in controlling microbial contaminants.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. Addition a disinfectant may help control microbial contaminants.

Action Level: The concentration of a contaminant, which, if exceeded, triggers treatment or other requirements, which a water system must follow.

90th Percentile: Ninety percent of the samples are below the action level. (Nine of ten sites sampled were at or below this level).

Treatment Technique (TT): A process aimed to reduce the level of a contaminant in drinking water.

Parts per million (ppm) or Milligrams per liter (mg/l): (one penny in ten thousand dollars)

Parts per billion (ppb) or Micrograms per liter (µg/l): (one penny in ten million dollars)

Picocuries per liter (pCi/L): a measure of radioactivity in water

Nephelometric Turbidity Unit (NTU): NTU is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to an average person.

Running Annual Average (RAA): Annual Level of Disinfection By-products (i.e. chlorination)

N/A: Not applicable

The table(s) below lists all the drinking water contaminants that were detected during the 2013 calendar year. It also includes the date and results of any contaminants that we detected within the past five years, of those which require testing less than once a year. The presence of these contaminants in the water does not necessarily show that our water poses a health risk.

Violation(s) that occurred during Calendar Year 2013

Type	Category	Analyte	Compliance Period
No Violations Occurred in Calendar Year 2013			

We are required to monitor our drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. The table above indicates any drinking water violations we incurred during 2013. A failure to perform required monitoring means we cannot be sure of the quality of our water during that time in which we did not perform required monitoring. WFD #1 has an excellent history of adhering closely to the rules & regulations regarding required water testing.

WATER QUALITY DATA

Level of Detected Contaminants

<u>Microbiological</u>	Result	MCL	MCLG	Typical Source
No Detected Results During Calendar Year 2013				

<u>Chemical Contaminant</u>	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Likely source of detected contaminant
Iron	09/27/2011	.11	.11 - .11	ppm			
Nitrate	03/26/2013	.048	.048-.048	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.

<u>Regulated Radionuclides</u>	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Likely source of detected contaminant
No Detected Results in the Calendar Year 2013							

<u>Regulated Disinfection By-Products</u>	Monitoring Period	RAA	Range	Unit	MCL	MCLG	Likely source of detected contaminant
Total Trihalomethanes	2008-2010	2	0-2.2	ppb	80	0	By-product of drinking water chlorination

<u>Lead & Copper</u>	Sampling Date	90 th Percentile	95 th Percentile	Range	Action Level	No. of Sites Exceeding Action Level	Likely source of detected contaminant
Copper	2013	0.064	0.065	0.031-0.067	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead	2013	0	0	0-0	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

Health Information Regarding Lead:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Westford Fire District #1 is responsible for providing high quality drinking water, but cannot control the variety of materials used in household plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>

Health Information Regarding Drinking Water:

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants, can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from EPA's Safe Drinking Water Hotline (1-800-426-4791) or at <http://www.epa.gov/safewater/lead>.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Safe Drinking Water Hotline.

Owner/Operator and Public Participation Opportunities

If you have any questions about this report or concerning your water quality, please contact the person(s) listed below. We want you to be informed about your water quality, if you want to learn more, please visit our website at www.wfd1.org or attend any of our regularly scheduled meetings, which are held at board member's homes. Please contact R.J. Moore for meeting locations and times.

R.J. Moore, Chairman, Westford Fire District #1
PO Box 103, Westford VT 05494
802.355.9308
rjm@wfd1.org

Randy L. Devine, Water System Operator
PO Box 402, Fairfax VT 05454-0402
Phone: 802.849.6304 or 802.849.6033